



TEST REPORT

Date: 12/30/2010

TEST NUMBER: 135074

CLIENT	Altro Floor and Wall Systems
--------	------------------------------

TEST METHOD CONDUCTED	ASTM F925-02 5 Minute Standard Test Method for Resistance to Chemicals of Resilient Flooring
-----------------------	--

DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Altro Quartz Tile Flooring
COLOR	Terracotta
ROLL	-----
CONSTRUCTION	-----
FIBER	-----
BACKING	-----
REFERENCE	

TEST RESULTS

5 MINUTE RATINGS

STAINING AGENT	SURFACE DULLING	SURFACE ATTACK	COLOR CHANGE
5% Acetic Acid	0	0	0
70% Isopropyl Alcohol	0	0	0
Mineral Oil	0	0	0
5% Sodium Hydroxide	0	0	0
5% Hydrochloric Acid	0	0	0
5% Ammonia	0	0	0
Bleach	0	0	0
5% Phenol	1	0	1
Gasoline	1	0	1
Sulfuric Acid	0	0	0
Kerosene	1	0	0
Olive Oil	1	0	0

RATING KEY
0 - No change (----)
1 - Slight change
2 - Moderate change
3 - Severe change

APPROVED BY: *Gary Colburn*

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.



TEST REPORT

Date: 12/30/2010

TEST NUMBER: 135074

CLIENT	Altro Floor and Wall Systems
--------	------------------------------

TEST METHOD CONDUCTED	ASTM F925-02 24 Hour Standard Test Method for Resistance to Chemicals of Resilient Flooring
-----------------------	---

DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Altro Quartz Tile Flooring
COLOR	Terracotta
ROLL	-----
CONSTRUCTION	-----
FIBER	-----
BACKING	-----
REFERENCE	

TEST RESULTS

24 HOUR RATINGS

STAINING AGENT	SURFACE DULLING	SURFACE ATTACK	COLOR CHANGE
5% Acetic Acid	0	0	0
70% Isopropyl Alcohol	0	0	0
Mineral Oil	0	0	0
5% Sodium Hydroxide	0	0	0
5% Hydrochloric Acid	0	0	0
5% Ammonia	0	0	0
Bleach	0	0	0
5% Phenol	1	0	1
Gasoline	1	0	1
Sulfuric Acid	0	0	0
Kerosene	1	0	1
Olive Oil	1	0	1

RATING KEY
0 - No change (----)
1 - Slight change
2 - Moderate change
3 - Severe change

APPROVED BY: *Gary Anthony*

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.