



eurofins

Attestation

On 8 May 2013 Eurofins Product Testing A/S received a sample of a rigid PVC sheet with the name

**Altro Whiterock
Altro USA Inc.**

The applied method complies with the method "Standard method for the testing and evaluation of volatile organic chemical emissions from indoor sources using environmental chambers (version 1.1)" as defined by the California Department of Public Health (CDPH) - Version of February 2010.

See test report 2013-392-00004301.

Evaluation of the test result according to CDPH Section 01350:

- No carcinogens and reproductive/developmental toxins could be detected.
- No individual compound exceeds one-half of the lowest concentration of interest in a building (chronic REL).

The tested product complies with the requirements of the "Standard method for the testing and evaluation of volatile organic chemical emissions from indoor sources using environmental chambers (version 1.1)" as defined by the California Department of Public Health (CDPH) - Version of February 2010.

06 June 2013

Dr. Arja Valtanen
Analytical Service Manager

Eurofins Product Testing A/S
Smedeskovvej 38
DK-8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75