



TEST REPORT

DATE: 08/27/2012

TEST NUMBER: 150638

CLIENT	Altro Floor and Wall Systems
--------	------------------------------

TEST METHOD CONDUCTED	ASTM F925-02 5 Minute Standard Test Method for Resistance to Chemicals of Resilient Flooring
-----------------------	--

DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Lavencia Plus
CONSTRUCTION	Vinyl Plank

TEST RESULTS

5 MINUTE RATINGS

STAINING AGENT	SURFACE DULLING	SURFACE ATTACK	COLOR CHANGE
5% Acetic Acid	0	0	0
70% Isopropyl Alcohol	0	0	0
Mineral Oil	0	0	0
5% Sodium Hydroxide	0	0	0
5% Hydrochloric Acid	0	0	0
5% Ammonia	0	0	0
Bleach	0	0	0
5% Phenol	0	0	0
Gasoline	0	0	0
Sulfuric Acid	0	0	0
Kerosene	0	0	0
Olive Oil	0	0	0

RATING KEY
0 - No change (----)
1 - Slight change
2 - Moderate change
3 - Severe change

APPROVED BY: *Gary Anthony*

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.



TEST REPORT

DATE: 08/27/2012

TEST NUMBER: 150638

CLIENT	Altro Floor and Wall Systems
--------	------------------------------

TEST METHOD CONDUCTED	ASTM F925-02 24 Hour Standard Test Method for Resistance to Chemicals of Resilient Flooring
-----------------------	---


DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Lavencia Plus
CONSTRUCTION	Vinyl Plank

TEST RESULTS

24 HOUR RATINGS

STAINING AGENT	SURFACE DULLING	SURFACE ATTACK	COLOR CHANGE
5% Acetic Acid	0	0	0
70% Isopropyl Alcohol	0	0	0
Mineral Oil	0	0	0
5% Sodium Hydroxide	0	0	0
5% Hydrochloric Acid	0	0	0
5% Ammonia	0	0	0
Bleach	0	0	0
5% Phenol	0	0	0
Gasoline	0	0	0
Sulfuric Acid	0	0	0
Kerosene	0	0	0
Olive Oil	0	0	0

RATING KEY
0 - No change (---)
1 - Slight change
2 - Moderate change
3 - Severe change

APPROVED BY: 

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.